



Council of Enviro Excellence



5TH NATIONAL POWER-GEN ENERGY EFFICIENCY

SUMMIT AND AWARDS 2025

Enhancing Efficiency in Indian Thermal Power Plants

**ENERGY EFFICIENT TECHNOLOGIES FOR THERMAL
POWER PLANTS- A DECARBONIZATION JOURNEY
FOR FOSSIL FUELS BASED ELECTRICITY**

MR. AMITABH SRIVASTAVA

5th National Power-Gen Energy Efficiency Summit

Optimizing Heat Rate: Enhancing Efficiency in Indian Thermal Power Plants



AMITABH SRIVASTAVA

BEE Accredited & Certified Energy Auditor

Sustainability Solutions Manager – Honeywell Automation India Ltd

Climate change : Change in the average surface temperature on Earth. The average temp. on our planet has been 15°C , but the past few years have seen drastic variations in the same, both up and down

REASON : Overexploitation of fossil fuels by humans and deforestation

RESULT: Release of carbon dioxide & other greenhouse gases, such as methane and nitrous oxide, into the atmosphere

1. Rise in the sea level
2. Extreme weather conditions
3. Melting polar ice
4. Floods
5. Droughts causing wildfires



What is Heat Rate?

The heat rate is defined as the total amount of energy required to produce one kilowatt-hour (kWh) of electricity by an electric generator or power plant


$$\text{Heat Rate} = \frac{\text{Thermal Energy Input}}{\text{Electric Energy Output}}$$

Relation between efficiency and heat rate


$$\text{Efficiency} \propto 1 / \text{Heat Rate}$$

If a power plant converted 100% of the chemical energy in the fuel into electricity, the plant would have a heat rate of 860 kcal/kWh.

Coal Based Thermal Power Plant Schematic Diagram




Important Components of Typical Coal Based Thermal Power Plant



Heat & Mass Balance Diagram

Turbine Cycle Heat Rate




Typical Auxiliary Power consumption in Thermal Power Plant


Equipment Ref.	500 MW		210 MW		110 MW	
	% Gen	% APC	% Gen	% APC	% Gen	% APC
BFP	0.00*	0.00*	2.70	33.60	2.94	24.50
CEP	0.40	5.70	0.27	3.34	0.36	3.00
CWP	1.00	14.20	0.66	8.31	1.26	10.50
IDF	1.30	18.70	1.26	15.80	1.71	14.23
PAF	0.60	8.50	0.68	6.50	1.78	14.46
FDF	0.30	4.10	0.40	5.00	0.26	2.13
Mills	0.60	8.20	0.58	7.23	0.83	6.92
CT fans	0.23	3.20	0.32	3.54	0.48	4.00
Air Comp.	0.08	1.20	0.12	1.56	0.24	2.00
A/C Plant	0.04	0.50	0.08	0.94	0.11	0.92
CHP	0.12	1.70	0.14	1.70	0.29	2.41
AHP	0.09	1.20	0.13	1.66	0.31	2.54
Lighting	0.06	0.80	0.08	1.00	0.08	0.68
others	2.23	31.90	0.60	7.44	1.36	11.32
APC	7.00	100.00	8.00	100.00	12.00	100.00

BFP – Boiler feed pump, CEP – Condensate extraction pump, CWP - Cooling water pump, IDF – Induced draft fan, PAF – Primary air fan, FDF – Forced draft fan, CT fans – Cooling tower fans, CHP – Coal handling plant, AHP – Ash handling plant, APC – Auxiliary power consumption and % Gen - % Generation.


Coal Fired Power Plant Boiler



UNIT OVERVIEW




FEED WATER CYCLE



TURBINE CYCLE & EXTRACTIONS

SPEED : **3007.4** RPM
 LOAD : **214.26** MW

SLC WATER
 INJ OFF



ENERGY EFFICIENCY

Energy Audit : Methodology

- Audit Step 1 : Data Collection
- Audit Step 2 : Observation, measurement & trials
- Audit Step 3 : Data Analysis & Findings
- Audit Step 4 : Implementing some of the measures and evaluation by trials (Online at equipment)
- Audit Step 5 : Recommendations & Techno-economic evaluation
- Audit Step 6 : Presentation to Top management & Detailed report preparation
- Audit Step 7 : Implementation Action plan preparation & Periodic Review

Electrical	Thermal
<p>Collecting the information on inventory of the electrical equipment installed and its operating parameters (like hours, actual load in kW etc.)</p> <p><u>Equipment / Sections</u></p> <ul style="list-style-type: none"> • Electrical Systems-Transformer • Electric Motor & Drives • Pump , Fan & Blower • Chiller compressor • Compressed Air System (Generation, Distribution & Utilization) • Lighting System • Harmonic analysis <p>Review of Loading parameters / reasons for deviations analyzed.</p>	<p>Collecting the information on inventory of the thermal installed and its operating parameters (like hours, Capacity, etc.)</p> <p><u>Equipment / Sections</u></p> <ul style="list-style-type: none"> • Boilers & Steam System • Steam Turbine • Deareator • Condenser • LP Heaters • HP Heaters • Refrigeration & Air-conditioning • Cooling Tower • <p>Energy & Mass balances carried out and user end requirements matched with installed capacities.</p>


ENERGY EFFICIENCY

Online Measuring Instruments

- Load Manager and Harmonic Analyzer
- Anemometer
- Ultrasonic Flow meter
- Digital Thermometer
- Infrared Thermometer
- Flue Gas Analyzer
- Pressure gauge
- Digital manometer
- Ultrasonic leak detector
- Lux Meter, etc.




Heat Pump Working




Proven system

WATER SOURCE HEAT PUMP



Case Study – 1 Installation of Water source Heat Pump for Boiler Feed water Preheating

BOILER FEED WATER DETAILS



Case Study – 1 Installation of Water source Heat Pump for Boiler Feed water Preheating

Boiler No.	Make	Capacity (TPH)	Operating Pr. (kg/cm ²)	Fuel Used
1	CVL	90	87	Coal
2	CVL	90	87	Coal
3	CVL	34	32	Coal
4	CVL	25	32	Coal

Table 1 List of Boilers

Existing Scenario

Two 90 TPH Boiler is running;

28 TPH of makeup water is supplied at ambient temperature to the deaerator, where it is heated to 105°C using steam extracted by Steam Turbine.

Inlet Make up Water temperature = 25°C to 30 °C

Outlet Make up Water temperature = 80°C

Parameter	UOM	Value
Feed Water Temperature	oC	25
GCV of Fuel (Indian Coal)	kCal/kg	3600
Make up Feed Water flow-rate	TPH	28
Operating days per year	days	324
Annual Steam consumption	Tons/year	20160
Steam generation rate	Rs/kg	2.2
Annual Energy spend for Boiler Make-up water preheating	Rs. Lakh	443.5
Heat pump Electricity consumption	kWh/year	5503741
Heat pump Electricity consumption Cost	Rs Lakh/year	220.15
Annual Chilling TRH production	TRH/year	195668
Electricity consumption for Chilling TRH producing	kWh/year	156534
Net Electricity Consumption by Heat pump	kWh/year	5347207
Electricity Rate Rs/ kWh	Rs/kWh	4
Net Electricity consumption cost by New Heat pump per year after Chilling as byproduct	Rs Lakh/year	213.9
Steam is passed through turbine , more kWh generation	kWh/year	570000

Case Study – 1 Installation of Water source Heat Pump for Boiler Feed water Preheating

Parameter	UOM	Value
Annual Monetary benefit with Electrical power generation	Rs Lakh/year	22.8
Net Monetary Benefit per year	Rs Lakh/year	252.4
Investment for Heat pump installation & Integration with Chilled water system	Rs Lakh	400
Payback period	Years	1.58

- Heating Output by Heat pump **Coal Saved**
- Chilling Output by Heat pump -Load on existing Chiller is reduced
- Steam reduction in Inefficient process of Deaerator
- Turbine more Electricity generation by saved steam
- GHG emission reduction **2250 Ton/year**

AFBC		WHRB-1		WHRB-2			
56.63	TPH	MS FLOW	5.69	TPH	MS FLOW	7.41	TPH
190.26	°C	MS TEMP	504.00	°C	MS TEMP	489.96	°C
62.46	KG/CM2	MS PRES	64.19	KG/CM2	MS PR	64.09	KG/CM2
52.43	%	DRM LVI	51.6	%	DRM LVI	49.81	%

TURBINE OPERATION

ALARM HOOTER PAGE


TURBINE		TURBINE			
LOAD	16961	KW	MS FLOW	67.23	TPH
RPM	7437.3	RPM	MS TEMP	483.48	°C
LO PR	2.94	KG/CM2	MS PRES	60.94	KG/CM2
VACCUM	-0.85	KG/CM2	EXH TEMI	51.95	°C

VACCUM PR	-0.8521	Kg/cm2	TC IL PR	60.94	Kg/cm2
EXHAUST TEMP	51.95	DegC	TC IL TMP	483.48	DegC
SSC	3.96	T/MW	TUR EFF	31.3	%
			HEAT RATE	2746	KCAL

HP DMD	45.38
ACT POS FB	45.37
SPD REF	7589
FREQ	50.01

LOAD
LOAD RAISE
LOAD LOWER

ACC-1 ACC-2
ACC-4 ACC-5
TEMP
BFP-1 OP PERM SPD CUR DP
BFP-2 OP PERM SPD CUR DP
BFP-3 OP PERM SPD CUR DP
BFP-4 OP PERM SPD CUR DP
INTIAL DMP-1
ACW-1 ACW DIS PR



104PCV01
CSDH VENT CV

SV
▲
▼
MODE
A

PV SV OP FB
SV 61.96 Kg/cm2
OP 0.0 %
FB 0.6 %

PIC_160	
PV	0.1 KG/CM2
SP	0.1 KG/CM2
Out	0.2 %

TRIP OIL PRESSURE	1.30	Kg/cm2
CONTROL OIL HDR PR.	22.66	Kg/cm2
LUBE OIL HDR PR	2.94	Kg/cm2
LUB OIL TMP AFR CLR	44.91	DegC
ALT COLD AIR TEMP-1	38.01	DegC
ALT HOT AIR TEMP-2	50.00	DegC

Case Study – 2 Energy Efficiency

Reduction of Air Ingress into Flue gas by arresting APH Leakages

Air leakage occurs in the APH because of the pressure difference between the high-pressure air and the low pressure exiting flue gases. The air leaks into the flue gas stream and exists to the stack resulting as follows:

- **Energy loss of hot air**
- **Pressure loss of hot air**
- **Additional load on the ID fan**

Result :

The flue gas temperature at the APH outlet increases on account of this besides resulting in reduced boiler efficiency and increased auxiliary power of the fans.

Improvement Measures during shut-down

- **Replacement of worn out seals –radial, axial & bypass**
- **Adjustment of radial sector plates to maintain gap**
- **APH water washing**

Reduction of Air Ingress into Flue gas by arresting

Parameter	Unit	APH A	APH B
Oxygen level at Inlet	%	2.8	3.4
Oxygen level at Outlet	%	4.6	5.1
Air Leakage	%	10.98	10.69
Average Leakage	%	10.83	
Optimum Leakage	%	6.00	
Improvement in Boiler Efficiency	%	0.55	
Coal GCV	kCal/kg	5400	
Annual Coal saving	Tonne	3334.3	
Annual Monetary saving	Rs. Lakh	166.7	
Investment	Rs. Lakh	75.0	
Payback Period	months	5.4	

Case Study – 3 Energy Efficiency

Installation of Sonic soot blowers in place of Steam soot blowers



Existing Condition : Air Pre-heater soot blowing is done by steam - Inefficient system

Energy Saving Potential : APH Soot blowing by Sonic Soot Blower results in reduction of steam consumption

Sonic soot blowing is cleaning of fouled surfaces by compressed air operated sonic soot blowers.

Sound waves sent inside boiler propagate in all directions and impart energy to ash particulates which fluidize and jump up from fouled surfaces to be carried away by the flue gas stream.

Cleaning is effective even deep into tube bundles leaving no dead corners unclean.



Parameters		Unit	Operating
Steam consumption in APH Soot Blowing		TPD	17
Steam enthalpy		kCal/kg	766
Annual energy saving		kCal	3904306
Coal GCV		kCal/kg	3400
Annual Coal saving		Tonne	1148
Annual Monetary saving		Rs Lakh	24.1
Additional power consumption		kW	60
with compressor			
Annual Energy consumption due to		kWh	150000
compressor			
Annual Monetary for consumption due to		Rs Lakh	1.5
compressor			
Annual Net Monetary Saving		Rs Lakh	22.6
Investment for Sonic Soot Blowers		Rs Lakh	15
Payback period		months	8.0

Case Study – 4 Energy Efficiency

Stoppage of one Vacuum pump in Unit Normal operation by arresting Air leakages in Condenser system

Existing Condition: In normal plant operation, both vacuum pumps are found I operation to meet vacuum requirement of Condenser

Design Condition : The plant is designed for operating one vacuum pump with one stand by pump.

Type of Condenser	Surface Condenser
No. of Condenser	1
Water Quality	Sea Water
Cooling ater Flow-rate	70000 TPH
Condense Back pressure	76 mmHg-a




● Performance of Condenser

- Vacuum is deteriorated due to very high air ingress in Condenser, plant is operating two vacuum pump instead of one pump operation as per design.

Parameter	Unit	Design	Operating
Condenser Duty	kCal/hr	680461505	703212324
Condenser Pressure	mmHg	75.98	92.68
Terminal Temperature Difference	oC	4.06	2.61
Energy Saving Potential			
Power consumption by Vacuum pump	kW	210	210 X 2
Annual Energy consumption	kWh	315000	630000
Annual Monetary saving	Rs. Lakh		6.93
Investment for Air arresting	Rs. Lakh		10.0
Payback period	months		11

Case Study – 5 Energy Efficiency

Proper insulation of Boiler, APH, Economiser & Steam Distribution network ,LP Heaters, HP Heaters, Deaerator




IR Image Information

Visual Image Information

Fig. No. : A 6

Location: Economizer Outlet



IR Image Information

Visual Image Information

Fig. No. : A 10


Location: After Economizer (3rd Floor)

Hot Insulation Survey by
Thermography Camera based on
Infrared Radiation Principle
To
Estimate Heat loss

Case Study – 5 Energy Efficiency

Heat Loss Estimation of uninsulated or weak insulated area of Boiler & Turbine area

Parameter	Unit	Value
Annual Insulation Heat Loss	Lakh kCal	29200
Coal GCV	kCal/kg	5400
Annual Coal saving	Tonne	54100
Annual Monetary saving	Rs. Lakh	27.0
Investment for proper insulation	Rs. Lakh	25.0
Payback period	months	11



Location: –Superheater outlet



THANK YOU